



June 14, 2018

**TO:** Bidders on IFB No. 18032D

**FROM:** City of Dayton, Ohio  
Division of Purchasing

**SUBJECT: ADDENDUM 2 - Questions and Answers for above IFB**

The City of Dayton has received questions relating to our IFB No. 18032D Emergency Generator with Removal and Installation Services.

The following are the questions with answers for this IFB. Please consider this document in preparation of your bid response. In the answers of these questions the City of Dayton shall be noted as "City".

To ensure the integrity of the bid process, a signed copy of this bid addendum notice shall be included with your company's response to this document.

\_\_\_\_\_  
(Print Name)

\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Company Name)

Sincerely,

Donita Jo Garner, CPPB  
Senior Buyer



**CITY OF DAYTON**  
**INVITATION FOR BID (IFB) NO. 18032D**  
**EMERGENCY GENERATOR WITH REMOVAL AND INSTALLATION SERVICES**  
**June 2018**

In the answers of these questions the City of Dayton shall be noted as "City".

The bid with all Addendums can be located at <http://www.daytonohio.gov/bids.aspx>

1. What is to be done with the old generator and associated switchgear?

**ANSWER:** The Department of Fire will retain possession of the generator. When it is removed we will have a trailer on site for the contractor to place the generator on.

2. The temperature rise rating of 105 degrees Celsius or a Class "B" rating is a direct conflict with each other. The Kohler alternator model data sheet for our 100kW generator option can be either a "Class B" rating or 105 degrees but not both. Typically the Class "F" at 130 degrees or Class "H" at 125 degrees is listed for standby generator systems like those used in Fire Departments. Kohler will price the class "H" model at 130 degrees C.

**ANSWER:** Please review IFB No. 18032D Addendum 1 Changes to Specifications, Section "Specification Removals", and Item 1.

This specification has been removed from the original bid.

3. Could I please get a some clarification on the following items.  
Generator voltage should be 120/240 single phase.

Generator alternator should be 130 degree rise alternator

Transfer switch should be 2 pole not three pole.

Natural gas generator option can be bid. City will need to verify if there is enough gas volume

**ANSWER:** Please review IFB No. 18032D Addendum 1 Changes to Specifications, Section "Specification Changes", and Items 1, 3, 4 and 5.

Provide one new 120/240 V generator 100 kW Single Phase.

The alternator shall be rated at a minimum Standby Class F.

Provide one new 400 Amp 2 pole Automatic Transfer Switch (ATS) that is Service Entrance Rated meeting the national electric code.

Yes, the City will do verification of gas volume.

4. Would you please provide copies of sign in sheets for site visit?

**ANSWER:** Voluntary site visit sign in sheet for this bid is included.



SITE VISIT SIGN-IN SHEET

IFB #18032D

Date: 06/05/2018

Time: 8:30 A.M.

Location: Fire Station 14

PLEASE PRINT LEGIBLY

NAME and EMAIL ADDRESS	COMPANY NAME	TELEPHONE NUMBER
Audrea Bashaw <sup>andrea.bashaw@</sup> ASIDACO	ASIDACO, LLC	937-234-7944



SITE VISIT SIGN-IN SHEET

IFB #18032D

Date: 06/05/2018

Time: 8:30 A.M.

Location: Fire Station 14

PLEASE PRINT LEGIBLY

NAME and EMAIL ADDRESS	COMPANY NAME	TELEPHONE NUMBER
Ty WILKINSON - Ohio CAT TALKING <sup>Ohio</sup> CAT. <sub>COM</sub> 1281 BRUNER DR, TROY OH 45420	Ohio CAT - Emergency Power	937-440-2710
Jeff Collins Joco135@hotmail.com	York Electric, Inc	937-760-7015
KEVIN KUNTE	COD	
KEITH MAKI	DAYTON FIRE BUILDING MAINT.	



SITE VISIT SIGN-IN SHEET

IFB #18032D

Date: 06/05/2018

Time: 8:30 A.M.

Location: Fire Station 14

PLEASE PRINT LEGIBLY

NAME and EMAIL ADDRESS	COMPANY NAME	TELEPHONE NUMBER
Mark Perls markb@active-electric.com	Active Electric	937-299-1805
Joe Hutchinson JHutchinson@PMTech.org	PM Tech	937-952-9236
Josh Golden JGolden@Jeffbonhamelectric.com	Bonham Electric	937-620-6620
Andrew Braun	COD	
Nicole Fox	COD	
DONITA JO GARNER donita.garner@daytonohio.gov	CITY OF DAYTON OH DIVISION OF PROCUREMENT	937-333-4035