



September 9, 2021

TO: Bidders on I.F.B. No. 21044S
FROM: City of Dayton, Ohio
Division of Purchasing
SUBJECT: **Addendum No. 1 to above IFB – Date Change and Clarifications**

The City of Dayton has received a question relating to our Invitation for Bid (“I.F.B.”) No.21044S.

The following are questions with answers for this I.F.B. Please consider this document in preparation of your bid response. In the answers of these questions the City of Dayton shall be noted as “City”.

The new due date for this IFB will be no later than 10:00 AM on September 17, 2021.

To ensure the integrity of the bid process, a signed copy of this addendum notice should be included with any bid offered to the City of Dayton as a result of IFB No. 21044S.

(Print Name)

(Date)

(Signature)

(Company Name)

Sincerely,

Jason Schortgen

Jason Schortgen



**CITY OF DAYTON
INVITATION FOR BID (IFB) NO. 21044S
Filter Console Replacement
September 2021**

At this time, the City, Division of Procurement will not be accepting any additional questions regarding this solicitation. All bids submitted on or before the opening date and time will be considered for acceptance.

Below are some clarifications that arose during the option site visit on September 8, 2021:

- There will be no bonding needed for this work.
- The City will provide wire / conduit.
- 3-4 consoles can be down / worked on at a time.
- The City will take care of updating the software and getting it online once installed.